

ADMINISTRATION

JACQUELYN L. KELLY
SUPERINTENDENT OF SCHOOLS
(315) 287-4870

JESSICA SULLIVAN
ASSISTANT SUPERINTENDENT
(315) 287-4870

DALE MUNN
BUSINESS MANAGER
(315) 287-4836

**GOUVERNEUR CENTRAL
SCHOOL DISTRICT**

133 East Barney Street
Gouverneur, New York 13642
FAX: (315) 287-4736

www.gcsk12.org

Delivering the Promise of a Brighter Future

BOARD OF EDUCATION

DAVID FENLONG
PRESIDENT

TODD BATES
VICE-PRESIDENT

BROOKE BUSH
DR. WILLIAM CARTWRIGHT

TINA FRENCH

LISA MCGREGOR
NICKOLAS ORMASEN

LAURIE ROBERTS
LAURA SPICER

October 29, 2025

Dear Families:

Our district, with the assistance of the Jefferson-Lewis BOCES Health and Safety Office, took samples from drinking water sources such as water bubblers, drinking fountains, and sinks typically used for water consumption. Additionally, such locations as custodial closet sinks, bathroom sinks, and other locations that are not typically used as sources of drinking water were also tested.

The results of the testing revealed lead concentration above the New York State Department of Health requirement of 5 parts per billion (ppb), which is equal to 5 micrograms per liter ($\mu\text{g/L}$), in some areas of the Gouverneur High School and the Gouverneur Elementary School. I received the results on Tuesday, October 28, at 10:00 a.m. The buildings and grounds department placed non-potable water signage at all outlets that tested above the action level (5 ppb) to the affected areas. Please be assured that all students and staff still have locations for water such as drinking fountains that tested below the limit.

The "on-again, off-again" nature of water use at schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. All outlets that tested above the action level (5 ppb) will be retested, allowing for a more regular and continuous use of all outlets.

To view all the results for the Gouverneur High School, please see the enclosed document or visit our web page at www.gcsk12.org.

Please feel free to contact my office with any questions or concerns.

Sincerely,


Jacquelyn L. Kelly
Superintendent of Schools